

## **AX25RT Treatment System - Gravity Discharge**



\* Primary Tank - Top View

AX25 800 gal. Recirc. Tank - Top View



\* Primary Tank - Side View

AX25 800 gal. Recirc. Tank - Side View

Discharge Chamber - End View

Copyright © 2013 Orenco Systems®, Inc.

## UNAUTHORIZED CHANGES & USES

Orenco has prepared these drawings for use by the design engineer. Orenco will not be responsible or liable for unauthorized changes to or uses of these drawings. All changes to these drawings must be made in writing and must be approved by the design engineer

\* 1,250 Gallons minimum capacity for 5 bedrooms 1,500 Gallons minimum capacity for 6 bedrooms.

PRODUCT CONFIGURATION DRAWINGS



Drawn By: <i>Ben Smith</i>	Project:	AV25DT Made 2A	Scale: I" = 2'-0"	
Drawn For:		AX25RT Mode 3A	Sheet:	I OF I
	Title:	NDW-ATX-RT-STD-24	Rev: <b>A-02</b>	Date: <b>4/22/2013</b>

Flow Control Disk with Orifice Installed Here

To Septic Tank or First Compartment of Processing Tank High Level Alarm High Level Override Redundant Off / Low Level Alar

Filter Tank Dry Weight: 950 lbs

0

**Control Panel Detail** Not To Scale

> Discharge Detail Not To Scale

Liquid Level Invert

of Tank)

Orenco Recirc.

(35" from Bottom

Design Notes

Authorized Installer only.

bedrooms.

VeriComm®

Control Panel

For residential strength waste up to 6

Installation to be performed by an AdvanTex

Start-up and service to be performed by an AdvanTex Authorized Service Provider only.

-Discharge (see detail) 42.5" 41" 32.5" Exterior Invert (35" is Actual Invert

28' of Outlet, see detail)

Pump System