

**NORTH CAROLINA DEPARTMENT OF HEALTH AND HUMAN SERVICES  
DIVISION OF PUBLIC HEALTH  
ENVIRONMENTAL HEALTH SECTION  
ON-SITE WATER PROTECTION BRANCH**

<b>INNOVATIVE WASTEWATER SYSTEM APPROVAL</b>
--

Innovative Wastewater System Approval Number: IWWS 2009-01-R2

Issued To:                   Infiltrator Systems, Inc.  
                                  PO Box 768  
                                  Old Saybrook, CT 06475  
                                  www.infiltratorwater.com

Contact:                    Jeanne Allen  
                                  800-221-4436

For:                            Aquaworx Pressure Bell Assembly and accompanying IPC-Series Control Panels:  
                                  Part numbers TRN-40, TRN-80, TRN-120, TRN-120, TRN-180, TRN-240, and TRN-  
                                  300

Approval Dates:           February 23, 2009  
                                  December 31, 2024        Updated for 18E and renewed for 2025  
                                  December 31, 2025        Renewed for 2026

In accordance with G.S. 130A-343 and 15A NCAC 18E Section .1700, an application by Infiltrator Water Technologies, LLC, for a renewal of their Aquaworx Pressure Bell Assembly for use with the accompanying IPC-Series Control Panels and accessory components, has been reviewed and found to meet the requirements of an innovative component when the following conditions are met.

I.    General

The scope of this Innovative approval is for the use, design, and installation requirements for the Aquaworx Pressure Bell Assembly and accompanying IPC-Series control panels.

II.   System Description

The Aquaworx Pressure Bell designed to replace mercury and mechanical floats and their wires in a wastewater system pump tank. The companion IPC-Series control panel works with the pressure bell and controls the pump and alarm functions in response to varying water levels in the pump tank as sensed by the pressure bell. The control panel is connected to the pressure bell by the transducer signal line made of UL recognized industrial tray cable which may be installed by direct bury or through an electrical conduit between the pump tank and the panel.

The controller is responsive to the transducer and programable effluent level thresholds. It also features a patented auto clear feature that is used to automatically replenish the air pocket in the

pressure bell housing, thereby protecting the transducer from waterlogging and maintaining accurate pump tank liquid level readings.

The control panel includes built in high level and transducer failure alarms (audible and visible). The panel also includes hand off automatic operation modes. The required method of installation utilizes a disconnect external to the control panel as per the National Electrical Code or local electrical codes.

### III. Design Criteria

- A. The pressure bell housing shall be of one-piece molded construction. It shall be molded of black ABS or PVC plastic. The differential pressure transducer assembly and PVC mounting fitting shall be bonded to the pressure bell housing using dielectric epoxy and shall be factory installed into the pressure bell housing at the factory with no user field replacement of the internal parts.
- B. Printed circuit boards are manufactured and provide a data logging with a date/time clock backup.
- C. The transducer assembly works on the principal that an increasing liquid level in the dosing tank compresses the air inside of the pressure bell housing. That pressure exerts a force on the transducer, which converts the pressure into an electrical signal. That electrical signal is transmitted through industrial tray cable back to the control panel where the circuit board microchip programming interprets the signal and accurately determines real time liquid levels. End users can read the depth through the use of the MARC controller display, palm pilot or laptop computer.
- D. The control panel is UL listed as an Industrial Control Panel (508A) and includes the standard features of a NEMA 4X enclosure; separate alarm and control circuits, grounding lugs, adjustable pump off, pump on, and high-level alarm; alarm test/silence push button; and pump hand run push button. Also includes as optional features: lockable latches and circuit breakers for control and motor circuits that are accessible inside the panel door.
- E. The panel utilizes a removable MARC or other controller, which shall enable the operator to set and display elapsed run time and cycle counter for each pump. Users can also use the MARC controller to access up to 4,000 stored data logged events such as dose events, manual run events, power failure events, and several alarm conditions. This is imperative when trouble shooting a system to assure proper system settings. The MARC/HUI controller is used to precisely adjust pump on/off and alarm activation levels based on the real time liquid level setting in the panel.
- F. Except as provided for herein, all other applicable requirements of 15A NCAC 18E .1103 shall be met.

### IV. Installation

- A. The control system shall be installed in accordance with manufacturer specifications.

Aquaworx shall supply as a complete package:

1. the pressure bell with cabling length as required
2. the control panel
3. polyurethane tubing pressure reference snorkel tubing of sufficient length to install into the dosing tank riser without splicing

- B. The Pressure Bell shall be securely mounted with a bracket or method approved by Aquaworx, Inc. and readily removable for adjustment or maintenance. The pressure bell shall be attached to a section of 1-inch stand pipe secured inside of pump-tank riser, with mounting bracket within 12-inches of the top of the riser. The bottom of Pressure Bell shall be located at approximately one dose above the top of the pump to prevent exposure of the pump during the autoclear cycle. The support pipe shall be secured in the mounting bracket so that there is adequate length of pipe above the bracket, to allow for the lowering of the bell to the system designers specification. An alternate means of securing the pressure bell meeting performance requirements as specified herein may be proposed by the authorized installer if concurred with by the manufacturer and approved by the local health department.
- C. The pressure reference snorkel tube shall be extended up through the 1-inch bell-securing pipe into the riser, and out to form an inverted J. The transducer signal line wire shall be connected to the control panel through sealed conduit with a minimum diameter of one half-inch. A junction box inside the dosing tank may only be used to serve as a wire pull-through and collection point for connection to the conduit to the control panel. No splices shall be made in either the poly-tubing or pump wire. Splices in the wire may be allowed for repairs using a method approved by Aquaworx.
- D. The control panel shall be securely mounted within 500 feet of the pump tank and at a height to allow the owner and operator to readily adjust and observe the liquid depth through the display on the MARC controller. The control panel must be in the line of sight of the system.
- E. Pump off, on and high-water alarm activation levels are set by using the button settings on the face of the MARC controller. Precise adjustments can be made using the MARC controller setup instructions per manufacturer's manual.

#### V. Operation and Maintenance

- A. An audible and visible alarm shall activate if any of the following conditions arise:
1. the Pressure Bell is disconnected from the controller for any reason; or
  2. the effluent level rises above the programmed pump-on level to the alarm level.

The 1.5-volt battery back-up system will keep the internal clock functioning in the event of a power failure at the controller. Repairs or replacement of malfunctioning components shall be completed in accordance with the manufacturer's recommendations.

- B. The 1.5-volt battery shall be replaced at least once every five years
- C. If operation of the Pressure Bell Assembly is affected by grease, floating debris, or in any other

way fails to operate as described, this approval may be amended or revoked.

VI. Responsibilities

- A. The Aquaworx installers shall be authorized in writing by the manufacturer to install this control system. The installer shall be at least a Level II or higher.
- B. Training by the manufacturer shall be provided, upon request, to local health departments to facilitate proper inspection and permitting of these systems.
- C. Duplex systems and grinder pump systems shall be designed by a North Carolina Professional Engineer if required in 15A NCAC 18E .0303(a).

Approved by: \_\_\_\_\_ Date: \_\_\_\_\_